

Floor Finishes Checklist (for floor tiles only)

Pursuant to The Street Works Act and its Regulations

State Material Used : _____ (eg granite, homogeneous tiles etc)

(✓) Tick the appropriate box for all items

Standard Requirements		Complied	Not Complied	Remarks
1.	The proposed finished floor shall provide a safe and hazard free environment. Any potential risks with appropriate mitigating measures shall be identified.	<input type="checkbox"/>	<input type="checkbox"/>	
2.	Submit full information on the proposed material for open walkways to be maintained by LTA. (brand/ country of origin/ name of manufacturer & supplier/ brochures/ product reference etc.)	<input type="checkbox"/>	<input type="checkbox"/>	
3.	Comply to Slip Resistance (Coefficient of friction for dry & wet.) SS485:2011 for "Slip resistance classification of public pedestrian surface materials".	<input type="checkbox"/>	<input type="checkbox"/>	
4.	Comply to surface hardness according to Moh's scale 7.	<input type="checkbox"/>	<input type="checkbox"/>	
5.	The material selected shall comply to the respective water absorption and compressive strength test requirements of a recognised regulatory body, eg SPRING Singapore.	<input type="checkbox"/>	<input type="checkbox"/>	
6.	The material selected shall have joints that are adequately spaced to cater for movement to prevent debonding.	<input type="checkbox"/>	<input type="checkbox"/>	
7.	The material selected shall comply with any applicable URA Development Control requirements for the particular location.	<input type="checkbox"/>	<input type="checkbox"/>	

Notes :

- The QP shall state the reasons for all non-compliances in the 'Remarks' column.
- A separate checklist shall be completed and submitted for each separate material.
- Nothing shall be construed to exempt any person from otherwise complying with the provision of the Street Works Act and its Regulations, the rules made thereunder and all other written laws for the time being in force.
- Any standard used for compliance must be recognised by SPRING Singapore.
- Test reports of floor materials are not required to be submitted.

Name Of Qualified Person

Signature Of Qualified Person

Date